

**DOCUMENT 003126**

**EXISTING HAZARDOUS MATERIAL INFORMATION**

1.1 EXISTING HAZARDOUS MATERIAL INFORMATION

- A. The Hazardous Materials Information documents are attached with this document.
- B. Related Requirements: Contractor is required to perform the Work in a manner complying with all applicable Federal, State and Local laws and regulations related to the materials identified in the report

**END OF SECTION 003126**



9830 South 51<sup>st</sup> Street, Suite B-109 / PHOENIX, ARIZONA 85044 / 480-940-5294 or 800-362-3373 / FAX 480-893-1726  
 emclab@emclabs.com

**LEAD (Pb) IN PAINT CHIP SAMPLES**  
**EMC SOP METHOD #L01/1 EPA SW-846 METHOD 7420**


<b>EMC LAB #:</b> L85883		<b>DATE RECEIVED:</b> 06/18/21			
<b>CLIENT:</b> M3 Environmental Consultants		<b>REPORT DATE:</b> 06/23/21			
		<b>DATE OF ANALYSIS:</b> 06/23/21			
<b>CLIENT ADDRESS:</b> 9821 Blue Larkspur Ln, Ste 100 Monterey, CA 93940		<b>P.O. NO.:</b>			
<b>PROJECT NAME:</b> Moss Landing Harbor – Pot Shop – ACM Pb Demo		<b>PROJECT NO.:</b> 21295.0 – T1			
EMC # L85883-	SAMPLE DATE /21	CLIENT SAMPLE #	DESCRIPTION	REPORTING LIMIT (%Pb by weight)	%Pb BY WEIGHT
1	06/17	L1	White – WB/JC – Wall – I	0.010	BRL
2	06/17	L2	Peach – Wood – Post – I	0.055	BRL
3	06/17	L3	Blue – Wood – Door – I	0.068	BRL
4	06/17	L4	Blue – Wood – Wall – I	0.065	BRL
5	06/17	L5	Peach – Wood – Wall – I	0.056	BRL
6	06/17	L6	Teal – Wood – Wall – I	0.031	BRL


^ = Dilution Factor Changed \* = Excessive Substrate May Bias Sample Results BRL = Below Reportable Limits # = Very Small Amount Of Sample Submitted, May Affect Result

This report applies to the standards or procedures identified and to the samples tested only. The test results are not necessarily indicative or representative of the qualities of the lot from which the sample was taken or of apparently identical or similar products, nor do they represent an ongoing quality assurance program unless so noted. Unless otherwise noted, all quality control analyses for the samples noted above were within acceptable limits.

Where it is noted that a sample with excessive substrate was submitted for laboratory analysis, such analysis may be biased. The lead content of such sample may, in actuality, be greater than reported. EMC makes no warranty, express or implied, as to the accuracy of the analysis of samples noted to have been submitted with excessive substrate. Resampling is recommended in such situations to verify original laboratory results. EMC Labs, Inc. (ID 101586) is accredited by the AIHA Laboratory Accreditation Programs, LLC (AIHA-LAP, LLC) in the Environmental Lead accreditation program(s) for Paint, Settled Dust by Wipe, Soil and Airborne Dust Fields of Testing as documented by the Scope of Accreditation Certificate and associated Scope. AIHA-LAP, LLC accreditation complies with the ISO/IEC Standard 17025:2005. requirements.

These reports are for the exclusive use of the addressed client and are rendered upon the condition that they will not be reproduced wholly or in part for advertising or other purposes over our signature or in connection with our name without special written permission. Samples not destroyed in testing are retained a maximum of sixty (60) days.

**ANALYST:**   
 Jason Thompson

**QA COORDINATOR:**   
 Kurt Kettler



9830 South 51<sup>st</sup> Street, Suite B-109 / PHOENIX, ARIZONA 85044 / 480-940-5294 or 800-362-3373 / FAX 480-893-1726  
 emclab@emclabs.com

**LEAD (Pb) IN PAINT CHIP SAMPLES**  
**EMC SOP METHOD #L01/1 EPA SW-846 METHOD 7420**


<b>EMC LAB #:</b> L85883		<b>DATE RECEIVED:</b> 06/18/21			
<b>CLIENT:</b> M3 Environmental Consultants		<b>REPORT DATE:</b> 06/23/21			
		<b>DATE OF ANALYSIS:</b> 06/23/21			
<b>CLIENT ADDRESS:</b> 9821 Blue Larkspur Ln, Ste 100 Monterey, CA 93940		<b>P.O. NO.:</b>			
<b>PROJECT NAME:</b> Moss Landing Harbor – Pot Shop – ACM Pb Demo		<b>PROJECT NO.:</b> 21295.0 – T1			
EMC # L85883-	SAMPLE DATE /21	CLIENT SAMPLE #	DESCRIPTION	REPORTING LIMIT (%Pb by weight)	%Pb BY WEIGHT
7	06/17	L7	Yellow – Wood – Wall – I	0.030	BRL
8	06/17	L8	Green – Wood – Wall – I	0.051	BRL
9	06/17	L9	Red – Wood – Wall – I	0.028	BRL
10	06/17	L10	Light Blue – Wood – Wall – I	0.031	BRL
11	06/17	L11	White – Wood – Cabinets – I	0.092	BRL
12	06/17	L12	White – Wood – Window Frame – I	0.053	BRL


^ = Dilution Factor Changed \* = Excessive Substrate May Bias Sample Results **BRL** = Below Reportable Limits # = Very Small Amount Of Sample Submitted, May Affect Result

This report applies to the standards or procedures identified and to the samples tested only. The test results are not necessarily indicative or representative of the qualities of the lot from which the sample was taken or of apparently identical or similar products, nor do they represent an ongoing quality assurance program unless so noted. Unless otherwise noted, all quality control analyses for the samples noted above were within acceptable limits.

Where it is noted that a sample with excessive substrate was submitted for laboratory analysis, such analysis may be biased. The lead content of such sample may, in actuality, be greater than reported. EMC makes no warranty, express or implied, as to the accuracy of the analysis of samples noted to have been submitted with excessive substrate. Resampling is recommended in such situations to verify original laboratory results. EMC Labs, Inc. (ID 101586) is accredited by the AIHA Laboratory Accreditation Programs, LLC (AIHA-LAP, LLC) in the Environmental Lead accreditation program(s) for Paint, Settled Dust by Wipe, Soil and Airborne Dust Fields of Testing as documented by the Scope of Accreditation Certificate and associated Scope. AIHA-LAP, LLC accreditation complies with the ISO/IEC Standard 17025:2005. requirements.

These reports are for the exclusive use of the addressed client and are rendered upon the condition that they will not be reproduced wholly or in part for advertising or other purposes over our signature or in connection with our name without special written permission. Samples not destroyed in testing are retained a maximum of sixty (60) days.

**ANALYST:**   
 \_\_\_\_\_  
 Jason Thompson

**QA COORDINATOR:**   
 \_\_\_\_\_  
 Kurt Kettler



9830 South 51<sup>st</sup> Street, Suite B-109 / PHOENIX, ARIZONA 85044 / 480-940-5294 or 800-362-3373 / FAX 480-893-1726  
 emclab@emclabs.com

**LEAD (Pb) IN PAINT CHIP SAMPLES**  
**EMC SOP METHOD #L01/1 EPA SW-846 METHOD 7420**


<b>EMC LAB #:</b> L85883		<b>DATE RECEIVED:</b> 06/18/21			
<b>CLIENT:</b> M3 Environmental Consultants		<b>REPORT DATE:</b> 06/23/21			
		<b>DATE OF ANALYSIS:</b> 06/23/21			
<b>CLIENT ADDRESS:</b> 9821 Blue Larkspur Ln, Ste 100 Monterey, CA 93940		<b>P.O. NO.:</b>			
<b>PROJECT NAME:</b> Moss Landing Harbor – Pot Shop – ACM Pb Demo		<b>PROJECT NO.:</b> 21295.0 – T1			
EMC # L85883-	SAMPLE DATE /21	CLIENT SAMPLE #	DESCRIPTION	REPORTING LIMIT (%Pb by weight)	%Pb BY WEIGHT
13	06/17	L13	White – Wood – Ceiling – I	0.040	0.998
14	06/17	L14	White – Wood – Post – I	0.083	1.15
15	06/17	L15	White – Wood – Window Frame – I	0.038	1.80
16	06/17	L16	Blue – Wood – Post – I	0.10	1.42 <sup>^</sup>
17	06/17	L17	White – Wood – Wall – I	0.012	BRL
18	06/17	L18	White – Stucco – Wall – I	0.010	BRL


<sup>^</sup> = Dilution Factor Changed \* = Excessive Substrate May Bias Sample Results BRL = Below Reportable Limits # = Very Small Amount Of Sample Submitted, May Affect Result

This report applies to the standards or procedures identified and to the samples tested only. The test results are not necessarily indicative or representative of the qualities of the lot from which the sample was taken or of apparently identical or similar products, nor do they represent an ongoing quality assurance program unless so noted. Unless otherwise noted, all quality control analyses for the samples noted above were within acceptable limits.

Where it is noted that a sample with excessive substrate was submitted for laboratory analysis, such analysis may be biased. The lead content of such sample may, in actuality, be greater than reported. EMC makes no warranty, express or implied, as to the accuracy of the analysis of samples noted to have been submitted with excessive substrate. Resampling is recommended in such situations to verify original laboratory results. EMC Labs, Inc. (ID 101586) is accredited by the AIHA Laboratory Accreditation Programs, LLC (AIHA-LAP, LLC) in the Environmental Lead accreditation program(s) for Paint, Settled Dust by Wipe, Soil and Airborne Dust Fields of Testing as documented by the Scope of Accreditation Certificate and associated Scope. AIHA-LAP, LLC accreditation complies with the ISO/IEC Standard 17025:2005. requirements.

These reports are for the exclusive use of the addressed client and are rendered upon the condition that they will not be reproduced wholly or in part for advertising or other purposes over our signature or in connection with our name without special written permission. Samples not destroyed in testing are retained a maximum of sixty (60) days.

**ANALYST:**   
 \_\_\_\_\_  
 Jason Thompson

**QA COORDINATOR:**   
 \_\_\_\_\_  
 Kurt Kettler



9830 South 51<sup>st</sup> Street, Suite B-109 / PHOENIX, ARIZONA 85044 / 480-940-5294 or 800-362-3373 / FAX 480-893-1726  
 emclab@emclabs.com

**LEAD (Pb) IN PAINT CHIP SAMPLES**  
**EMC SOP METHOD #L01/1 EPA SW-846 METHOD 7420**

<b>EMC LAB #:</b> L85883		<b>DATE RECEIVED:</b> 06/18/21			
<b>CLIENT:</b> M3 Environmental Consultants		<b>REPORT DATE:</b> 06/23/21			
		<b>DATE OF ANALYSIS:</b> 06/23/21			
<b>CLIENT ADDRESS:</b> 9821 Blue Larkspur Ln, Ste 100 Monterey, CA 93940		<b>P.O. NO.:</b>			
<b>PROJECT NAME:</b> Moss Landing Harbor – Pot Shop – ACM Pb Demo		<b>PROJECT NO.:</b> 21295.0 – T1			
<b>EMC #</b> L85883-	<b>SAMPLE DATE /21</b>	<b>CLIENT SAMPLE #</b>	<b>DESCRIPTION</b>	<b>REPORTING LIMIT</b> (%Pb by weight)	<b>%Pb BY WEIGHT</b>
19	06/17	L19	Orange – Stucco – Wall – J	0.010	BRL
20	06/17	L20	Gray – Wood – Wall – J	0.017	0.219

^ = Dilution Factor Changed \* = Excessive Substrate May Bias Sample Results **BRL** = Below Reportable Limits # = Very Small Amount Of Sample Submitted, May Affect Result

This report applies to the standards or procedures identified and to the samples tested only. The test results are not necessarily indicative or representative of the qualities of the lot from which the sample was taken or of apparently identical or similar products, nor do they represent an ongoing quality assurance program unless so noted. Unless otherwise noted, all quality control analyses for the samples noted above were within acceptable limits.

Where it is noted that a sample with excessive substrate was submitted for laboratory analysis, such analysis may be biased. The lead content of such sample may, in actuality, be greater than reported. EMC makes no warranty, express or implied, as to the accuracy of the analysis of samples noted to have been submitted with excessive substrate. Resampling is recommended in such situations to verify original laboratory results. EMC Labs, Inc. (ID 101586) is accredited by the AIHA Laboratory Accreditation Programs, LLC (AIHA-LAP, LLC) in the Environmental Lead accreditation program(s) for Paint, Settled Dust by Wipe, Soil and Airborne Dust Fields of Testing as documented by the Scope of Accreditation Certificate and associated Scope. AIHA-LAP, LLC accreditation complies with the ISO/IEC Standard 17025:2005. requirements.

These reports are for the exclusive use of the addressed client and are rendered upon the condition that they will not be reproduced wholly or in part for advertising or other purposes over our signature or in connection with our name without special written permission. Samples not destroyed in testing are retained a maximum of sixty (60) days.

**ANALYST:**

Jason Thompson

**QA COORDINATOR:**

Kurt Kettler

# EMC LABS, INC.

9830 S. 51st Street, Suite B109, Phoenix, AZ 85044  
Phone: 800-362-3373 or 480-940-5294 - Fax: (480) 893-1726

Laboratory Report

**0255702**

## Bulk Asbestos Analysis by Polarized Light Microscopy

NVLAP#101926-0

Client:	M3 ENVIRONMENTAL CONS.	Job# / P.O. #:	21295.0 T1
Address:	9821 BLUE LARKSPUR LN, STE 100 MONTEREY CA 93940	Date Received:	06/18/2021
Collected:	06/17/2021	Date Analyzed:	06/23/2021
Project Name:	MOSS LANDING HARBOR-POT SHOP	Date Reported:	06/23/2021
Address:	ACM Pb DEMO	EPA Method:	EPA 600/R-93/116
		Submitted By:	ALEX SUPERKO
		Collected By:	

Lab ID Client ID	Sample Location	Layer Name / Sample Description	Asbestos Detected	Asbestos Type (%)	Non-Asbestos Constituents
0255702-001 1A	FRONT	LAYER 1 12"x12" Vinyl Floor Tile, Off White w/ Line & Floral Pat	Yes	Chrysotile 2%	Carbonates Quartz Binder/Filler 98%
		LAYER 2 Mastic, Yellow	No	None Detected	Cellulose Fiber 1% Carbonates Quartz Gypsum Binder/Filler 99%
0255702-002 2A	FRONT	Wallboard/ Joint Compound Composite, White/ Brown/ Off White Note: COMPOSITE ANALYSIS	No	None Detected	Cellulose Fiber 11% Carbonates Gypsum Mica Quartz Perlite Binder/Filler 89%
0255702-003 2B	FRONT	Wallboard/ Joint Compound Composite, White/ Brown/ Off White Note: COMPOSITE ANALYSIS	No	None Detected	Cellulose Fiber 11% Carbonates Gypsum Mica Quartz Perlite Binder/Filler 89%
0255702-004 3A	FRONT	Bumpy Texture, White/ Off White	No	None Detected	Carbonates Quartz Perlite Binder/Filler 100%
0255702-005 3B	FRONT	Bumpy Texture, White/ Off White	No	None Detected	Carbonates Quartz Perlite Binder/Filler 100%

# EMC LABS, INC.

9830 S. 51st Street, Suite B109, Phoenix, AZ 85044  
Phone: 800-362-3373 or 480-940-5294 - Fax: (480) 893-1726

Laboratory Report  
**0255702**

## Bulk Asbestos Analysis by Polarized Light Microscopy

NVLAP#101926-0

Client: M3 ENVIRONMENTAL CONS. Job# / P.O. #: 21295.0 T1  
Address: 9821 BLUE LARKSPUR LN, STE 100 Date Received: 06/18/2021  
MONTEREY CA 93940 Date Analyzed: 06/23/2021  
Collected: 06/17/2021 Date Reported: 06/23/2021  
Project Name: MOSS LANDING HARBOR-POT SHOP EPA Method: EPA 600/R-93/116  
Address: ACM Pb DEMO Submitted By: ALEX SUPERKO  
Collected By:

Lab ID Client ID	Sample Location	Layer Name / Sample Description	Asbestos Detected	Asbestos Type (%)	Non-Asbestos Constituents
0255702-006 3C	FRONT	Bumpy Texture/ Paint, Silver Note: Sample is mainly Paint - little Texture present	No	None Detected	Carbonates Quartz Perlite Binder/Filler 100%
0255702-007 4A	BACK	LAYER 1 Unglazed Saltillo Tile, Red	No	None Detected	Gypsum Quartz Binder/Filler 100%
		LAYER 2 Grout, Gray	No	None Detected	Quartz Gypsum Carbonates Mica Binder/Filler 100%
0255702-008 5A	EXTERIOR	LAYER 1 Stucco-Scratch Coat, Gray	No	None Detected	Quartz Gypsum Mica Carbonates 100%
		LAYER 2 Stucco - Paint, Beige/ Off White	No	None Detected	Quartz Gypsum Carbonates Binder/Filler 100%

# EMC LABS, INC.

9830 S. 51st Street, Suite B109, Phoenix, AZ 85044  
Phone: 800-362-3373 or 480-940-5294 - Fax: (480) 893-1726

Laboratory Report

**0255702**

## Bulk Asbestos Analysis by Polarized Light Microscopy

NVLAP#101926-0

Client: M3 ENVIRONMENTAL CONS. Job# / P.O. #: 21295.0 T1  
Address: 9821 BLUE LARKSPUR LN, STE 100 Date Received: 06/18/2021  
MONTEREY CA 93940 Date Analyzed: 06/23/2021  
Collected: 06/17/2021 Date Reported: 06/23/2021  
Project Name: MOSS LANDING HARBOR-POT SHOP EPA Method: EPA 600/R-93/116  
Address: ACM Pb DEMO Submitted By: ALEX SUPERKO  
Collected By:

Lab ID Client ID	Sample Location	Layer Name / Sample Description	Asbestos Detected	Asbestos Type (%)	Non-Asbestos Constituents
0255702-009 5B	EXTERIOR	LAYER 1 Stucco-Scratch Coat, Gray	No	None Detected	Quartz Gypsum Mica Carbonates 100%
		LAYER 2 Stucco - Paint, Beige/ Off White	No	None Detected	Quartz Gypsum Carbonates Binder/Filler 100%
0255702-010 5C	EXTERIOR	LAYER 1 Stucco-Scratch Coat, Gray	No	None Detected	Quartz Gypsum Mica Carbonates 100%
		LAYER 2 Stucco - Paint, Beige/ Off White	No	None Detected	Quartz Gypsum Carbonates Binder/Filler 100%
0255702-011 6A	EXTERIOR	Window Putty, Gray	No	None Detected	Carbonates Quartz Binder/Filler 100%
0255702-012 6B	EXTERIOR	Window Putty, Gray	No	None Detected	Carbonates Quartz Binder/Filler 100%
0255702-013 7A	ROOF	Roof Rubber Sheet, Black	No	None Detected	Carbonates Quartz Binder/Filler 100%



# EMC LABS, INC.

9830 S. 51st Street, Suite B109, Phoenix, AZ 85044  
Phone: 800-362-3373 or 480-940-5294 - Fax: (480) 893-1726

Laboratory Report

**0255702**

## Bulk Asbestos Analysis by Polarized Light Microscopy

NVLAP#101926-0

Client:	M3 ENVIRONMENTAL CONS.	Job# / P.O. #:	21295.0 T1
Address:	9821 BLUE LARKSPUR LN, STE 100	Date Received:	06/18/2021
	MONTEREY CA 93940	Date Analyzed:	06/23/2021
Collected:	06/17/2021	Date Reported:	06/23/2021
Project Name:	MOSS LANDING HARBOR-POT SHOP	EPA Method:	EPA 600/R-93/116
Address:	ACM Pb DEMO	Submitted By:	ALEX SUPERKO
		Collected By:	

Lab ID Client ID	Sample Location	Layer Name / Sample Description	Asbestos Detected	Asbestos Type (%)	Non-Asbestos Constituents
0255702-014 7B	ROOF	Roof Rubber Sheet, Black	No	None Detected	Carbonates Quartz Binder/Filler 100%
0255702-015 8A	ROOF	LAYER 1 Roof Paint, Silver	No	None Detected	Carbonates Quartz Binder/Filler 100%
		LAYER 2 Penetration Mastic/ Tar, Black	No	None Detected	Cellulose Fiber Carbonates Quartz Binder/Filler <1% 99%



Analyst - Kurt Kettler



Signatory - Lab Manager - Ken Scheske

Distinctly stratified, easily separable layers of samples are analyzed as subsamples of the whole and are reported separately for each discernible layer. All analyses are derived from calibrated visual estimate and measured in area percent unless otherwise noted. The report applies to the standards or procedures identified and to the sample(s) tested. The test results are not necessarily indicative or representative of the qualities of the lot from which the sample was taken or of apparently identical or similar products, nor do they represent an ongoing quality assurance program unless so noted. These reports are for the exclusive use of the addressed client and that they will not be reproduced wholly or in part for advertising or other purposes over our signature or in connection with our name without special written permission. The report shall not be reproduced except in full, without written approval by our laboratory. The samples not destroyed in testing are retained a maximum of thirty days. The laboratory measurement of uncertainty for the test method is approximately less than 1 by area percent. Accredited by the National Institute of Standards and Technology, Voluntary Laboratory Accreditation Program for selected test method for asbestos. The accreditation or any reports generated by this laboratory in no way constitutes or implies product certification, approval, or endorsement by the National Institute of Standards and Technology. The report must not be used by the client to claim product certification, approval, or endorsement by NVLAP, NIST, or any agency of the Federal Government. Polarized Light Microscopy may not be consistently reliable in detecting asbestos in floor coverings and similar non-friable organically bound materials.